



ROOF PLAN KEYNOTES

- 1 ALL NEW STRUCTURES, AND EVERY EXISTING STRUCTURE WHEN 50% OR MORE OF THE TOTAL ROOF AREA IS RE-ROOFED WITHIN VERY HIGH FIRE HAZARD SEVERITY ZONES DESIGNATED BY THE CALIFORNIA DEPARTMENT OF FORESTRY AND FIRE PROTECTION, OR BY A LOCAL AGENCY, SHALL HAVE AT LEAST A CLASS 'A' ROOF COVERING. ROOF COVERINGS IN ALL OTHER AREAS SHALL HAVE A CLASS 'C' RETARDANT ROOF COVERING. (U.B.C. SEC. 1503.1)
- 2 ROOF DRAIN. RE: 6 / D2.
- 3 EARTHEN ROOF. SEE SHEET D2 FOR STANDARD DETAILS.
- 4 LINE OF ROOF & DRIP EDGE
- 5 AT THE JUNCTURE OF THE ROOF AND VERTICAL SURFACES, FLASHING AND COUNTERFLASHING SHALL BE PROVIDED PER THE ROOFING MANUFACTURER'S INSTRUCTIONS AND, WHEN OF METAL, SHALL NOT BE LESS THAN 0.019-INCH (NO. 26 GALVANIZED SHEET GAGE) CORROSION RESISTANT METAL. (U.B.C. SEC. 1509)
- 6 LINE OF WALL BELOW
- 7 CURVED TRI-D PANEL W/ SHOTCRETE ON BOTH SIDES AND PLASTER FINISH TO MATCH WALLS
- 8 STONE COPING ANCHORED TO PERFORM WALL, SLOPING AND DRIP EDGE BOTH SIDES, OVER METAL FLASHING OR AS RECOMMENDED PER MANUFACTURER (PHASE II)
- 9 CURB MOUNT SKYLIGHT, INSTALLATION AND FLASHING PER MANUFACTURER
- 10 TYPICAL 2x WD FRAME CONSTRUCTION, HEIGHT AS REQUIRED PER SKYLIGHT MANUFACTURER
- 11 GALVANIZED SCUPPERS

ROOF PLAN

